



NOTE: 1) HYDRO @ 325 PSIG. MIN.

HEADS		.289" SA-455 2:1 S.E.	
TRIM			
SHELL		.338" SA-455	
M.A.W.P.	250 PSIG. @	200 °F	
M.D.M.T.	-20 °F @	250 PSIG.	
ASME SECTION VIII DIV. 1, 2013			
X-RAY: RT-4 SPOT L.S. & HDS. G.S.			
GALLONS:	1999	WT. 4386 LBS.	
SERIAL NO.			
N.B.			
<b>PA-387-B</b>		REV. 3-27-14	
FOR: HANSON STANDARD		DATE: 3-9-99	
HORIZ. LPG TANK			
CFM REQ. = 5616			
SURFACE AREA = 290.7 SQ. FT.			
INSIDE: UNPAINTED & DEHYDRATE			
OUTSIDE: PRIME			
BY: E.S.	SCALE: 1/2"=12"		
<b>ROY E. HANSON JR. MFG.</b>			
1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021			