



NOTE: 1) HYDRO @ 327 PSIG. MIN.

SHELL / HEADS	.245" SA-455 2:1 S.E.
JOGGLE	
	.289" SA-455
M.A.W.P.	250 PSIG @ 200 °F
M.D.M.T.	-20 °F @ 250 PSIG.
ASME SECTION VIII	DIV. 1, 2004 ADD. 2005
X-RAY:	RT-4 SPOT L.S. & HDS. G.S.
GALLONS:	1150 WT. 2790 LBS.
SERIAL NO.	
N.B.	

PA-514-B	REV. 8-23-06
FOR: HANSON STANDARD	DATE: 1-2-90
HORIZ. PROPANE TANK DISPENSER	
CFM REQ. = 4033	
SURFACE AREA = 194.1 SQ. FT.	
INSIDE: UNPAINTED & DEHYDRATE	
OUTSIDE: PRIME	
BY: J.G.	SCALE: 1/2"=12"
ROY E. HANSON JR. MFG.	
1600 E. WASHINGTON BLVD.	
LOS ANGELES, CA 90021	