



NOTE: 1) HYDRO @ 327 PSIG. MIN.

HEADS	.245" SA-455 2:1 S.E.
JOGGLE	
SHELL	.289" SA-455
M.A.W.P.	250 PSIG @ 200 °F
M.D.M.T.	-20 °F @ 250 PSIG.
ASME SECTION VIII	DIV. 1, 2004 ADD. 2006
X-RAY:	RT-4 SPOT L.S. & HDS. G.S.
GALLONS:	1000 WT. 2329 LBS.
SERIAL NO.	
N.B.	

<b>PA-515-B</b>		REV. 8-14-07
FOR: HANSON STANDARD		DATE: 1-2-90
HORIZ. PROPANE TANK DISPENSER		
CFM REQ. = 3662		
SURFACE AREA = 172.5 SQ. FT.		
INSIDE:	UNPAINTED & DEHYDRATE	
OUTSIDE:	PRIME	
BY: J.G.	SCALE: 1/2"=12"	
<b>ROY E. HANSON JR. MFG.</b>		
1924 COMPTON AVE.		
LOS ANGELES, CA 90011		